EVAPCO, INC. UNIT DATE MODEL # SERIAL # **CLOSED CIRCUIT COOLER** NTS W2124012-MRC-SR 5/20/2024 ATC-105E NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS UPPER SECTION 2597 -— 2597 -**BOTTOM OUTLET** 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD (W) (M) 613 BFW DENOTES BEVELED FOR WELDING 4. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES) 5. 19mm DIA. MOUNTING HOLES. REFER TO 3607 RECOMMENDED STEEL SUPPORT DRAWING 6. THE SPRAY PUMP SHOULD BE SIZED FOR 177 L/S AND 17 kPa AT THE INLET CONNECTION 7. *- APPROXIMATE DIMENSIONS DO NOT USE FACE 1 FOR PRE-FABRICATION OF CONNECTING **PIPING** 8. SERIES FLOW PIPING AND AUX. CROSSOVER DRAIN BY OTHERS 12256 FACE 2 **PLAN VIEW −** 178 **-**─ 41 ---- 1740 --933 150 FPT -ACCESS ACCESS (M) - 150 FPT (4) INLET DOOR DOOR INLET 100 BFW FLUID IN SERIES FLOW 3153 (2) (2) **PIPING** 1213 15 FPT 15 FPT (SEE NOTE 8) (4) 5340 **VENT VENT** 100 BFW TYP. FLUID OUT AUX. - 133 CROSSOVER 2188 DRAIN (SEE NOTE 8) TYP. 3607 12256 FACE 1 FACE 2 NO. OF SHIPPING SECTIONS SHIPPING OPERATING HEAVIEST SECTION 33005 44480 14500 4 kq kg kq WEIGHT WEIGHT WEIGHT