EVAPCO, INC. UNIT MODEL # SERIAL # REV. **CLOSED CIRCUIT COOLER** NTS WZ09094810-MRA-SR 4/29/2024 eco-ATC-1001A NOTES: 1. (M)- FAN MOTOR LOCATION (M)2. HEAVIEST SECTION IS LOWER SECTION **BOTTOM** 3. MPT DENOTES MALE PIPE THREAD OUTLET FPT DENOTES FEMALE PIPE THREAD **─** 1365 **→** 460 BFW DENOTES BEVELED FOR WELDING 4. **+**UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES) 5. 19mm DIA. MOUNTING HOLES. REFER TO 2578 RECOMMENDED STEEL SUPPORT DRAWING 6. THE SPRAY PUMP SHOULD BE SIZED FOR 41 L/S AND 28 kPa AT THE INLET CONNECTION FACE 2 7. * - APPROXIMATE DIMENSIONS DO NOT USE FOR PRE-FABRICATION OF **PLAN VIEW** CONNECTING PIPING 8. SERIES FLOW CROSSOVER PIPING PROVIDED **INTERNALLY** 2731 FACE 1 - 502 ACCESS — 1289 – _(M)__| DOOR__! 35 2797 150 FPT INLET 5093 3874 15 FPT **VENT** 2296 - 100 BFW 876 FLUID IN 100 BFW FLUID OUT 511 860 → 860 2578 2731 -FACE 1 FACE 2 NO. OF SHIPPING SECTIONS **SHIPPING** OPERATING HEAVIEST SECTION 2 4425 5620 kg 2890 kq WEIGHT WEIGHT WEIGHT