| UNIT COOLING TOWER | FVADCO INC evapea | DWG. # AX122209-DRC-ST REV. |
|--|--|--|
| MODEL # SCALE AXS 12-11G22 | EVAPCO, INC. | SERIAL # DATE 5/5/2024 |
| NOTES: 1. (M)- FAN MOTOR LOCATION 2. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED 3. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS) 4. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa] 5. 3/4" DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING. 6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH IN [METRIC] [mm] | FACE B PLAN VIEW 5'-11" [1804] | FACE C CCESS DOOR |
| 7" [178] 11'-10" [3607] FACE B | 3 3/8" | 2" [50] MPT MAKE-UP 3" [80] FPT OVERFLOW 3" [80] FPT DRAIN 10'-1" [3073] 11'-4 1/2" [3467] FACE A |
| SHIPPING WEIGHT 11800 lbs+ [5355] kg+ OPERATING WEIGHT | 25990 lbs+ [11790] kg+ HEAVIEST SECTION 11800 lbs+ | [5355] kg+ NO. OF SHIPPING SECTIONS 1 DRAWN BY: JLM |