NIT OOOL ING TOWER		[]6	DWG.#	REV
COOLING TOWER	FVADCO 1	[Nic evapco	ATL4BI48304E5T-DRD-DS	-
AT 248-5Q30-EV SCALE N	EVAPCO, 1		SERIAL#	DATE: 5/19/2024
NOTES  1. (M)- FAN MOTOR LOCATION  2. HEAVIEST SECTION IS CASING SECTION  3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE  4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAW  5. 3/4" [19mm] DIA. MOUNTING HOLES. REFI RECOMMENDED STEEL SUPPORT DRAW  6. DIMENSIONS LISTED AS FOLLOWS ENGLISH FT-IN [METRIC] [mm]  7. FOR BOTTOM INLET SPECIFICATIONS, SEE DETAIL.	INGS) ER TO /ING 2 5/8" [67]	18'-2 1/2" [5550]  (M)  (2) ACCESS DOOR  FACE B  PLAN VIEW  DM OF UNIT  5'-11 3/8" [1813]  7'-6"	FACE C [10]	10 1/8" [3000]   14'-3 3/4" [4362]   (4) 16" [400]   BFW/GVD   EQUALIZER   FACE D
[14	-2'-1 1/4" [641] -1'-5 3/8" [441] -3 5/8" [92] -1'-11 3/4" [603] -2'-9 3/8" [848]	7'-0" [2134] 6'-0 1/8" [1832] 31'-9 1/2" [9690] 8'-7 1/8" [2619] 10'-2 1/4" [3105] FLUID OUT 1 3/8" [35]	3" [80] 13'-4 3/8" [4074] 30'-2 1/4" [9201]	_3'-0 3/8" [924]
SHIPPING 139200 lbs+ [63145] kg+	OPERATING 192260 lbs+ [87210] kg+	HEAVIEST SECTION WEIGHT 13200 lbs+ [5990] kg+	NO. OF SHIPPING SECTIONS 14	DRAWN BY: JLG